

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0801:172 Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Radionics, Div. Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199
Contact: Frank Mioduszewski *(585) 223-4060

DESIGN: Model D322 electronic fix temperature heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 134°F to 149°F Fix Temperature/Rate of Rise

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For ceiling mount only.

MARKING: Listee's name, model number, temperature rating and UL label.

APPROVAL: Listed as fix temperature heat detector for use with listee's Model D321 base (CSFM Listing No. 7300-0801:169) and separately listed Radionics' Model D10024 fire alarm control unit (CSFM Listing No. 7165-0801:166).

XLF: 7272-0410:146

*Rev. 05-31-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 31, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager